

Classification, use and evaluation of performance, according to CPR - EU Directive 305/11 and Spec. EN 50575/14

Euro-Class	B _{ca} s1a d1 a1	C _{ca} s1a d1 a1	C _{ca} s3 d1 a3	D _{ca} s1, d2, a1	E _{ca}	F _{ca}
Risk of Fire	high	middle-high	middle	middle-low	low	OUTDOOR installation and use ONLY
Performance of fire reaction						
Installation	in a bundle				individually installed	
Installation Place subject to each National specifications (acc. to DM139/15 in Italy)						
	under decision of the client or the designer	shopping centers hospitals cinemas schools offices > 25 people	residencial estate large offices workshops large storehouses garages	single residences small offices shops < 400 m ² small storehouses		
DoP Declaration of Performance	yes					
AVCP System Assessment Verification Constancy Performance system	1+			3		4